

Clarksdale Public Utilities

416 Third Street • PO Box 70 • Clarksdale, MS 38614
662-627-8499

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

CLARKSDALE PUBLIC UTILITIES Has levels of TTHM Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, our customers have a right to know what happened, what they should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. On March 12, 2025, we received a notice dated March 7, 2025, that the water system failed to comply with the standards for Disinfection By-Products samples according to the Safe Drinking Water Act during the monitoring period ending the 1st Quarter of 2025. The average samples at one of the eight sample collection sites showed that our system exceeded the standard or maximum contaminant level, (MCL), for TTHM (Total Trihalomethane). The standard for TTHM is 0.080 mg/L. The average level of TTHM during the 1st quarter of this year at one of the collection sites was 0.095 mg/L.

What should I do?

- There is nothing you need to do. **You do not need to boil your water** or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.

What is being done?

- We are working to minimize the formation of TTHM while ensuring we maintain an adequate level of disinfectant. We have taken additional steps to change disinfectant type/levels, remove natural organic matter, and increased flushing of water lines to determine if our efforts have been effective.
- We have purchased an automatic flushing device to flush our lines more often.
- We anticipate resolving the problem within the next several months.

For more information, please contact:

Leslie Wolf, Lead Customer Service Representative
662-627-8499

"Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail."

This notice is being sent to you by the CLARKSDALE PUBLIC UTILITIES.

State Water System ID# MS0140002

Date distributed: 3/24/25

"Building a Greater Clarksdale"